

FAILURE TO SUBMIT A DISINFECTANT LEVEL QUARTERLY OPERATING REPORT  
MONITORING, ROUTINE (DBP), MAJOR/CHLORINE

The West Jacksonville WSC water system PWS ID 0370036 has violated the monitoring/reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems are required to properly disinfect water before distribution, maintain acceptable disinfection residuals within the distribution system, monitor the disinfectant residual at various locations throughout the distribution system, and report the results of that monitoring to TCEQ on a quarterly basis.

Results of regular monitoring are an indicator of whether or not your drinking water is safe from microbial contamination.

This violation occurred in the monitoring period of the third quarter of 2021.

We are taking the following actions to address the issue: The quarterly report was completed and printed for TCEQ but they did not receive the submission. The report has subsequently been re-submitted. The daily residuals were actually taken and recorded properly with all daily recordings within acceptable limits a required by TCEQ. Form submissions in the future will be followed up within 5 business days to make sure they have been accepted/received by TCEQ.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e. people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have any questions regarding this matter, please contact Sammy Grimes at 903-539-3063.